ESWPM Addendum 1 Rev. 009

Callaway Energy Center – Ameren Hazardous Risk Categories (AHRC) for Arc Flash Exposure

Voltage and Bus	Bounding	Limited	Restricted	Incident	Arc Flash	Ameren
Classification	Fault	Approach	Approach	Energy	Boundary	Hazardous
	Location	Boundary	Boundary	(Cal/cm ²)		Risk Category
50-300 volts	PPPY331	3feet	Avoid	0.3	10 inches	AHRC 0
	LPPG111	6 inches	Contact			
301 - 600 Volts Load Side						
Molded Case Circuit Breaker	PG11J	3 feet	14 inches	7.9	6 feet	AHRC 2
(MCCs, etc)		6 inches				
301 – 600 Volts	PG133 /	3 feet	14 inches	13.7	11 feet	AHRC 3
	PG234	6 inches				
601 – 4160 Volts	PB04	5 feet	26 inches	22.2	60 feet	AHRC 3
>4160 – 13,800 Volts	SITE RING	5 feet	26 inches	26.4	72 feet	AHRC 4
345 KV (Open Air)	345 Open	15 feet	9 feet	Not	10 feet	AHRC 2*
	Air Line	4 inches	2 inches	Calculated		

Ameren Hazard Risk Categories		Arc Flash PPE Legend		
		Minimum PPE Requirements		
AHRC 0	(<1 cal /cm ²)	Non-arc rated PPE Appropriate natural fiber shirt with pants or coverall and safety glasses or goggles		
AHRC 1	(1 – 4 cal/cm ²)	Minimum Arc Rating 4 cal/cm² (As long as business segment's arc rated policy allows) Appropriate arc rated long sleeve shirt and pants or coverall; appropriate rated rubber gloves with protectors; safety glasses with arc rated face shield or flash hood; arc rated jacket, parka, or rainwear as needed; electric rated hard hat; safety glasses or goggles; primarily leather safety footwear; and hearing protection (ear canal inserts)		
		For AHRC 1 the shirt SHALL be tucked in at the pants and ALL neck and sleeve buttons SHALL be buttoned. This is NOT a requirement for AHRC 3, 4, or 5 when an arc rated suit is being worn over the top of the arc rated shirt and pants.		
AHRC 2	(>4 – 8 cal/cm ²)	Minimum Arc Rating 8 cal/cm ² Appropriate arc rated long sleeve shirt and pants or coveralls; appropriate rated rubber gloves with protectors; arc rated flash suit hood; arc rated jacket, parka, or rainwear as needed; electric rated hard hat; safety glasses or goggles; primarily leather safety footwear; and hearing protection (ear canal inserts)		
		For AHRC 2 the shirt SHALL be tucked in at the pants and ALL neck and sleeve buttons SHALL be buttoned. This is NOT a requirement for AHRC 3, 4, or 5 when an arc rated suit is being worn over the top of the arc rated shirt and pants.		
		Note: 8 cal/cm ² are rated balaclava and are rated face shield may be used as a substitute for the are rated flash suit hood. Properly wearing of the 8 cal/cm ² balaclava, buttoning of the top button of the are rated shirt is not required.		
AHRC 3	(>8 – 25 cal/cm ²)	Minimum Arc Rating 25 cal/cm ² Appropriate arc rated shirt and pants***; appropriate rated rubber gloves with protectors; arc rated flash suit jacket; arc rated flash suit pants; arc flash suit hood; arc rated jacket, parka, or rainwear as needed; electric rated hard hat (arc rated liner as required); safety glasses or goggles; primarily leather safety footwear; and hearing protection (ear canal inserts)		
AHRC 4	(>25 – 40 cal/cm ²)	Minimum Arc Rating 40 cal/cm ² Appropriate arc rated shirt and pants***; appropriate rated rubber gloves with protectors; arc rated flash suit jacket; arc rated flash suit pants; arc flash suit hood; arc rated jacket, parka, or rainwear as needed; electric rated hat (arc rated liner as required); safety glasses or goggles; primarily leather safety footwear; and hearing protection (ear canal inserts)		

ESWPM Addendum 1 Rev. 009

AHRC 5	(>40 – 100 cal/cm ²)	Minimum Arc Rating 100 cal/cm ² Appropriate arc rated shirt and pants***; appropriate rated rubber gloves with protectors; arc rated flash suit jacket; arc rated flash suit pants; arc flash suit hood; arc rated jacket, parka, or rainwear as needed; electric rated hard hat (arc rated liner as required); safety glasses or goggles; primarily leather safety footwear; and hearing protection (ear canal inserts)
AHRC 6	(over 100 cal/cm ²)	DO NOT WORK ENERGIZED
		All AC and DC Circuits at the Callaway Energy Center have been evaluated in the Arc Flash Study and the above boundary fault locations are the most limiting**

^{*} Required when crossing the Arc Flash Boundary

There is no established method to calculate an incident energy for protective clothing requirements, so based on an engineering recommendation and taking the conservative approach is why AHRC4 will be the required PPE when installing grounds on the Iso-Phase Bus when the plant is in a shutdown condition with the steam to the main turbine isolated with WPA Hold-Off tags, and the switchyard output breakers open with WPA Hold-Off tags, visual verification of double breaks, and that the 345 kV ground switch, MDV54G, is closed.

When the Iso-Phase is being fed from either the Generator side or the Switchyard side, the incident energy is greater than 40 cal/cm² so work can't be performed on the Iso-Phase when energized.

Reduction in Arc Flash PPE due to Plant Structural Components (CR 201509084):

Callaway Energy Center had site engineering do an evaluation which is documented in CA1 of CR 201509084, based on that review, the following Line of Sight from a potential Arc Flash Point will incorporate the following guidelines:

- 1. The plant structure would have to be constructed of sheet metal, structural steel, masonry, or concrete. The structure shall be at least 7 feet tall and 3 feet wide. The structure shall be stationary (non-movable) to prevent the structure from moving if an ARC flash occurred. If working in a cubicle, or racking a breaker in or out, then even with the above structures in place the individual shall be at least three cubicles away from the cubicle where the potential ARC flash could occur.
- 2. The PPE requirements when following the above guidelines would be reduced to standard PPE that is required for being in the power block of the Callaway Energy. However, if an individual is outside of the guidelines listed above, but within the AFB for the electrical component, then the required AHRC PPE will be required. These guidelines were reviewed and agreed upon by Operations, Engineering, Safety, and the Maintenance Electrical Manager.
- 3. Since the Safety Observer is required to be in continuous visual contact with the individual doing the electrical work, this recommendation can't be used by the Safety Observer

^{**} The table in section 5.2.1 of the ESWPM Rev. 4 for short circuit currents between 7 kA and 15 kA shall be used for the large batteries (NK, PK) and lines up to the first fuse box (AHRC 3).

^{***} At Callaway Energy Center 100% Natural Fiber Clothing meets the requirement for appropriate arc rated shirt and pants.