



Ameren's Minimum Approach Distance

Minimum Approach Distances for Voltages for 50 V to 362.0 kV		
NEW		
Table V-5—Alternative Minimum Approach Distances		
Nominal Voltage	Distance	
Phase-to-Phase	Phase-to-Ground Exposure	Phase-to-Phase Exposure
(kV)	Feet-Inches	Feet-Inches
0.05 to 0.300	Avoid Contact	Avoid Contact
0.301 to 0.750	1' 2"	1' 2"
0.751 to 5.0	2' 1"	2' 1"
5.1 to 15.0	2' 2"	2' 3"
15.1 to 36.0	2' 7"	3' 0"
36.1 to 46.0	2' 10"	3' 3"
46.1 to 72.5	3' 4"	4' 0"
72.6 to 121.0	3' 9"	4' 3"
121.1 to 145.0	3' 10 "	4' 10"
145.1 to 169.0	4' 4"	5' 5"
169.1 to 242.0	5' 8"	8' 5"
242.1 to 362.0	8' 6"	13' 6"