

40 CFR Parts 257

Checklist for Inspection Requirements for CCR Landfills 257.84 (b)


Labadie Power Station – LCL1 (Landfill Cell 1)

1. Annual Inspection

Requirements	Signs of actual or potential structural weakness	Disruptions or potential disruption to the operation and safety of the unit
CCR Unit and appurtenant structures 257.84(b)(ii)	None Observed	None Observed

The 2025 Annual Inspection included a review of available information regarding the status and condition of the CCR unit, including, but not limited to, files available in the operating record in general accordance with 257.84(b)(i).

Engineer's Seal



Alex Nash, P.E.

License: PE-2022038507

Date: January 15, 2026

LABADIE ENERGY CENTER
Cell 1 (LCL1) and Pond 1

Date	10/21/2025
Inspector	Alex Nash, Sean Walsh
Weather	Sunny
Temperature	60°F

Date of Previous Annual Inspection: 10/25/2024

Date of Previous Periodic Inspection: 10/27/2020

Description of Emergency (EC) or Immediate Maintenance (IM) conditions observed since the last annual inspection:

None

Describe any action taken to restore or improve safety and integrity of impounding structure:

None

Describe any modifications to the geometry of the impounding structure since the previous annual inspection:

None

Describe any modifications to the operation of the impounding structure since the previous annual inspection:

None

List the approximate remaining storage capacity of the impounding structure:
1,718,579 C.Y.

List the approximate maximum, minimum and present depth and elevation of the impounded CCR in Cell 1 since the previous annual inspection:

	Maximum		Minimum		Present	
	Elevation (ft)	Depth (ft)	Elevation (ft)	Depth (ft)	Elevation (ft)	Depth (ft)
Cell 1	490	12	488	10	490	12

Approximate volume of CCR at the time of the inspection:
381,421 C.Y.

Describe any changes to the downstream watershed:

None