

2026 Q3 DCS Change List

Standard	Revision Description
Section 3	
03 12 02 **	Added: new DCS 03 12 02 17 & 03 12 02 18 & 03 12 02 20.
	Added: Note 7 regarding composite pole ground location.
	Added: Note 8 regarding the DE angle limitations and spacing.
	Added: Note 9 regarding the pole grounding requirements.
	Updated: BOM materials for new standards and fixed some quantities for existing standards.
Section 5	
05 00 00 05 **	Revised: Fixed typo in Description table of the BOM
05 17 01**	New Standard: 05 17 01 02
	Revised: Note 2
	Added: New Note 4
Section 12	
12 34 01 **	BOM: Changed the description for the stock #10 01 158 to Arrestor, 72kV, 57kV MCOV.
Section 14	
14 00 20 **	Revised: Concrete and sonotube dimensions
	Revised: Notes 2 and 3
14 12 14	Revised: Corrected BOM Item H Stock number and Description
Section 15	
15 00 01 01	Corrected: LED 100W equivalent instead of 400W on page 3.
	Removed: HID decorative post top luminaire for Colonial and Early post top.
	Revised: CCT to 2700K for contemporary and Aspen post tops
	Corrected: Stock numbers for Acorn Post Top.
	Corrected: Stock numbers for the directional luminaires on page 8.
15 70 18 01	Added: Dimension to the mounting plate for the 15 ft bracket.
15 74 01	Added: Molding to staple the street lighting wire on the pole as optional.
	Revised: Lag screw from 1/2" to 3/8".
15 74 02	Added: Molding to staple the street lighting wire on the pole as optional.
	Revised: Lag screw from 1/2" to 3/8".
Section 16	
16 80 01**	Added: clarity to the source /load sides of wiring connection to each bushing of the recloser.
	Revised: Corrected dimension of the bypass switch mouned on the pole.
	Added: Construction note 11.
16 80 02**	Moved from Maintenance & Limited Use.
	Added: Construction notes 8 & 9
	Moved neutral to deadend on the pole instead of on the crossarm.
	BOML Chaned item B from stock #2368440 to stock #2359064 - Link Figure 8.
16 80 03 01	Changed: Relocated bypass switches on the opposite side of the regulator bank.
	Revised: Construction note 4
	Added: Construction notes 12, 13 & 14.
	Added: Design notes 16 & 17.
16 80 10**	New Standard: 35kV 3-Phase Regulator Platform Mounted.
Section 19	
	New Section
Section 29	
29 00 01 01	Added: service drop information to note G.
	Revised: drawings for power supply
Section 33	
33 12 01 XX	Removed: CMP and replaced with precast concrete riser section.
	Removed: poured concrete.
	Updated: BOM to include precast riser and precast flat top lid section.
Section 59	
59 40 00 12	Added: Table 4 (34 kV Cable Ratings)
	Added: Table 5 (69 kV Cable Ratings)