



SECTION A A

NOTE: AMEREN MISSOURI REP. WILL DESIGNATE THE QUADRANT OF THE POLE WHERE THE CONDUIT IS TO BE INSTALLED.

↗ MATERIAL INSTALLED BY CONTRACTOR FOR ONE RISER
 (DERIVED FROM CONSTRUCTION STANDARD 14 00 26 **)

	Stk. No.	Description	Qty.
A	12 51 331	Bend - 1-1/2" x 24" Rad (Streetlight)	1
	12 51 173	Bend - 3" x 36" Rad (Primary and Secondary)	1
	12 51 206	Bend - 5", 36" Rad (3 Phase Primary)	1