

STRUCTURES – CONDUIT
Conduit – Direct Buried Drainage Pit
(When Required For Water Problems)




FIG. 1
FOR BURIED ELECTRICAL PLASTIC CONDUIT

FIG. 2
FOR BURIED PLASTIC CONDUIT AT LOWEST POINT IN RUN




FIG. 3
FOR CONCRETE ENCASED PLASTIC CONDUIT AT LOWEST POINT IN RUN

MATERIAL INSTALLED BY CONTRACTOR

(DERIVED FROM CONSTRUCTION STANDARD 31 47 02 **)

Material / Stk. No.	Description	Conduit Size		
		Quantity		
		1-1/2"	3"	5"
	Conduit Perforated 30" long	1 Ea	1 Ea	1 Ea
	Backhoe 42" in ft.	3'	3'	3'
	Rock Crushed	As Req'd	As Req'd	As Req'd